

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, Troja, 182 00 Praha 8

CERTIFICATE

No.: 2180008

Ordering firm: KOPOS KOLÍN a.s.
Havlíčková 432, Kolín IV, 280 02 Kolín, Czech Republic

Manufacturer/Licence holder: KOPOS KOLÍN a.s.
Havlíčková 432, Kolín IV, 280 02 Kolín, Czech Republic

Production site: KOPOS KOLÍN a.s.
Havlíčková 432, Kolín IV, 280 02 Kolín, Czech Republic

Name of product: Cable protective conduit systems HDPE and accessories

Trade name:

Type of product: 06xxx (see Annex)

Rating: diameter 16-75 mm

Electrotechnical Testing Institute on the basis of fulfillment the requirements of the „ESČ Mark” certification scheme is granting a licence for using the following mark



This mark may be used for the product specified in this certificate within validity of the Agreement on the use of the ESČ Mark by implementing all the rules stated in the Agreement.

The right to use the above mentioned mark for the product is based on:

- Test report No. 704618-01/01 of: 13.02.2018

A sample of the product was tested and found to be in conformity with:

ČSN EN 61386-1 ed. 2:09, ČSN EN 61386-24:11,
ČSN EN ISO 9969:16

- inspection at manufacturing site according to Permanent Documents CIG 023 and CIG 024 No. 700539-01 of: 11.04.2017
- the Agreement on the use of the ESČ Mark No. 704618 concluded between the ordering firm and the Electrotechnical Testing Institute

Other data:

23.02.2018 Corr. 24.04.2024

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



704618-01

Jednoplášťové chráničky HDPE	spojky	koncovky
Cable protective conduit systems HDPE	couplings	endings
06016	05016	05015, 05017
06020	05020	05019, 05021
06025	05025	05024, 05026
06032	05030, 05033	05031, 05032
06040	05040, 05043	05041, 05042
06050	05050, 05053	05051, 05052
06063	05063	05062, 05064
06075	05075	05074, 05076

24.04.2024

